

Wash Station Inspection Checklist

Conduct safety inspections for the emergency wash stations at your construction site to ensure they are safe to use in case of accidental hazards. Use this checklist to complete a thorough inspection of your wash stations to ensure they comply with safety regulations and Occupational Safety and Health Administration (OSHA) guidelines. Use the digital checklist from Fulcrum to customize this checklist to suit your needs. Find the digital version of this form and more at <https://www.fulcrumapp.com/apps/wash-station-inspection-checklist>.

General

Type of Inspection
Choose one.

Eyewash

Shower

Location of Inspection

Street Address

City, State, Zip

Requirement

ACCESS

- ▶ Is there an unobstructed passage and easy access to the eyewash/shower station?
 Yes No
- ▶ Is the area well lit and easily visible?
 Yes No
- ▶ Is there enough room to allow the user to stand in front of the eyewash station nozzles and maintain their eyes open, or to stand below the flushing fluid stream of a shower?
 Yes No
- ▶ Is the eyewash/shower located within 10 sec (55 feet) from potential hazardous materials?
 Yes No

- ▶ Is the eyewash/shower location identified with a highly visible sign?
 Yes No

EMERGENCY UNIT

- ▶ Are eyewash nozzles equipped with protective covers?
 Yes No
- ▶ Are the covers automatically removed upon activation of the eyewash?
 Yes No
- ▶ Is the eyewash/shower unit easily activated?
 Yes No
- ▶ Does the unit activate in less than 1 second?
 Yes No
- ▶ Once activated, does the unit remain operational without the use of the hands?
 Yes No
- ▶ Does the unit allow for a continuous flow of flushing fluid for more than 15 minutes?
 Yes No
- ▶ Are there any signs of corrosion to the unit?
 Yes No

WATER FLOW

- ▶ Does the eyewash spray pattern deliver a simultaneous flow of water to both eyes?
 Yes No
- ▶ Does the shower spray pattern deliver a continuous flow of water with a diameter of at least 50 cm (20") at 152 cm (60") from the floor?
 Yes No
- ▶ Does the eyewash water flow at a volume not less than 1.5 liter (0.4 gallons) per minute for 15 minutes?
 Yes No

- ▶ Does the shower water flow at a volume not less than 75 liters (20 gallons) per minute for 15 minutes?
 Yes No

- ▶ Is the flow rate at a low velocity to be non-injurious to the user?
 Yes No

- ▶ Is the water temperature constant and tepid? Temperature range: 16-38 °C (60.8-100.4 °F)
 Yes No

- ▶ Is the flushing liquid clear?
 Yes No

- ▶ Does the flow remain until the unit is returned to its resting position?
 Yes No

- ▶ Does the water drain properly from the basin/sink?
 Yes No

Certification

Passed? Pass Fail

Name of inspector
Please print

Signature

Date

_____ / _____ / _____

Time

_____ : _____ **AM / PM**



Fulcrum is a mobile app creation platform that lets you digitize checklists like this easily — and automate related workflows! — without writing any code.

Check us out at fulcrumapp.com/checklists